

Certificate No.: SGS/240187

# CERTIFICATE OF SUITABILITY

This certificate is issued by **SGS Australia Pty Ltd** in accordance with the SGS Electrical Type Testing Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065. SGS certifies the electrical equipment described hereunder complies with the standard/s listed herein. It is a requirement that the electrical equipment supplied under this certificate shall be identical to the electrical equipment as certified. The electrical equipment may be marked with the regulatory compliance mark (RCM) in accordance with its conditions of use as set out in AS/NZS 4417.1 and the authorised marking as specified herein.

## CERTIFICATE HOLDER

Company Name: Stiebel Eltron (Aust) Pty Ltd  
Address: 294 Salmon Street, 3207, PORT MELBOURNE, Victoria, Australia

## CERTIFICATION DETAILS

Certification Standard: AS/NZS 60335.2.40:2023 and AS/NZS 60335.1:2020 + A1  
Comments/ Conditions: Suitable for sale in Australia / New Zealand  
Authorised Marking: SGS-240187-E  
Certificate Issue Date: 29 July 2024  
Certificate Expiry Date: 28 July 2029

## ELECTRICAL EQUIPMENT

Description: Air / Water Heat Pump

Trade Name	Model Number	Ratings
Stiebel Eltron	WPL 25 AC	400 V a.c.; 7.1 KW; 50 Hz; IP14; Refrigerant: R410a / 5.50 kg; Class I; Max. pressure 4.5 MPa; Supplementary heater (DHC): 8.8 kW
Stiebel Eltron	WPL 25 ACS	230 V a.c.; 6.9 KW; 50 Hz; IP14, Refrigerant: R410a / 5.50 kg, Class I, Max. pressure 4.5 MPa; Supplementary heater (DHC): 6.2 kW



For and On Behalf of  
SGS Australia Pty Ltd

